

Type 1+2 AC surge protector 3-phase

DS253E-120



- Type 1 + 2 unipolar surge protector
- Iimp total: 75 kA on 10/350µs impulse
- Imax : 140 kA on 8/20µs impulse
- Internal disconnections, status indicators
- Remote signaling
- IEC 61643-11, EN 61643-11 and UL1449 ed.5 compliance





V: High-energy varistor
Ft: Thermal fuse
C: Remote signal contact
t°: Thermal disconnection system
MI: Disconnection indicator

Electrical Characteristics		
SPD type	IEC	1+2
Network		120/208 V
AC system		TNC
Nominal line voltage	Un	120 Vac
Max. AC operating voltage	Uc	150 Vac
Max. load current *if series connection*	IL	100 A
Temporary Over Voltage (TOV) Characteristics - 5 sec. *Without disconnection*	UT	180 Vac withstand
Temporary Over Voltage (TOV) Characteristics - 120 mn *Without disconnection or with safety disconnection*	UT	230 Vac disconnection
Residual Current *Leakage current to Ground*	Ipe	< 3 mA
Follow current	If	None
Nominal discharge current *15 x 8/20 µs impulses*	In	70 kA
Max. discharge current *max. withstand @ 8/20 µs by pole*	Imax	140 kA
Impulse current by pole *max. withstand 10/350µs by pole*	Iimp	25 kA
Total lightning current *max. total withstand @ 10/350µs*	Itotal	75 kA
Specific energy by pole *max. withstand 10/350 µs*	W/R	156 kJ/ohm
Connection mode(s)		L/PE
Protection mode(s)		Common mode
Protection level L/PE *@ In (8/20µs)*	Up L/PE	1 kV
Admissible short-circuit current	Isccr	50 000 A
Mechanical Characteristics		
Technology		MOV
SPD configuration		2-poles
Connection to Network		By screw terminals: 6-35mm² / by bus
Format		1-pole modular box assembled
Mounting		Symmetrical rail 35 mm (EN 60715)
Housing material		Thermoplastic UL94 V-0
Operating temperature	Tu	-40/+85°C
Protection rating		IP20
Failsafe mode		Disconnection from AC network
Disconnection indicator		3 mechanical indicators by pole
Remote signaling of disconnection		Output on changeover contact
Dimensions		See diagram
Disconnectors		
Thermal disconnector		Internal
Installation ground fault breaker		Type 'S' or delayed
Back-up protection device		Fuse assembly: SFD1-25-30S / or Fuses Type gG 315 A
Standards		
Standards compliance		IEC 61643-11 / EN 61643-11 / UL1449 ed.5
Certification		
Part number		
3887		